

DZR Commissioning Set



Flow Data and Installation Instructions

Flow Coefficient

The flow rate can be calculated using the Kv value and a measured signal.

$$K_v = \frac{Q \cdot 36}{\sqrt{\Delta P}} \quad K_{vs} = \frac{Q \cdot 36}{\sqrt{\Delta P_s}}$$

where K_v & K_{vs} = flow coefficient (m³/hr at 1 bar differential)

Q = flow rate (l/s)

ΔP = headloss attributable to valve (kPa)

ΔP_s = differential pressure across tapplings (signal) (kPa)

Kvs Values

Size	½"	¾"	1"	1¼"	1½"	2"
K _{vs}	1.8	4.1	7.5	16.6	23.0	47.4

Pressure Loss

The pressure loss across a metering station is less than signal differential pressure indicated on the flow charts. The pressure loss is obtained by multiplying the pressure signal by the pressure recovery factors given in the table.

This applies to when the metering station is used in a stand alone application or close coupled to a double regulating valve.

Pressure Recovery Factors

Size	½"	¾"	1"	1¼"	1½"	2"
Factor	0.67	0.5	0.5	0.5	0.5	0.4

Pressure Loss


The pressure losses for the ART 26 double regulating valves are given on the individual flow charts along with the corresponding Kv values at the various positions open.

Installation

Metering stations must always be installed with a minimum of 5 pipe diameters of straight pipe, without intrusion, upstream of the metering station.

Downstream of the metering station a minimum of 2 pipe diameters of straight pipe are required.

When close coupled to an Albion ART 26 double regulating valves only the straight pipe upstream of the metering station is required.



Sizing

Once the required flow rate has been calculated, the size of the metering station can be determined based on the following:

The minimum signal at the design flow rate of 1 kPa.



For minimum pressure loss, a maximum signal of 4.7 kPa, which corresponds to the maximum differential pressure range of a fluorocarbon manometer.

Pressure Equipment Directive

Under the Pressure Equipment Directive (PED) these metering stations and double regulating valves have been specified for Group 2 Liquids i.e. non-hazardous

Sizes ½" to 2" are classified as SEP (Sound Engineering Practice)

1/2" ART 27 DZR Metering Station



Signal / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_{vs} \sqrt{\Delta p}}{36}$$


Where

Q = Flowrate l/s


Δp = Signal kPa

K_{vs} = Signal Co-efficient

1/2" ART 26 DZR Double Regulating Valve



Position	2	3	4	5	6	7	8
Kv	0.69	0.99	1.3	1.5	1.7	1.8	1.9



Pressure Loss / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_v \sqrt{\Delta p}}{36}$$



Where

Q = Flowrate l/s

Δp = Pressure Loss kPa

Kv = Pressure Loss Co-efficient

3/4" ART 27 DZR Metering Station



Signal / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_{vs} \sqrt{\Delta p}}{36}$$


Where

Q = Flowrate l/s


Δp = Signal kPa

K_{vs} = Signal Co-efficient

3/4" ART 26 DZR Double Regulating Valve



Position	2	3	4	5	6	7	8
Kv	1.0	1.7	2.6	3.4	3.9	4.3	4.4



Pressure Loss / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_v \sqrt{\Delta p}}{36}$$



Where

Q = Flowrate l/s

Δp = Pressure Loss kPa

Kv = Pressure Loss Co-efficient

1" ART 27 DZR Metering Station



Signal / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_{vs} \sqrt{\Delta p}}{36}$$


Where

Q = Flowrate l/s


Δp = Signal kPa

K_{vs} = Signal Co-efficient

1" ART 26 DZR Double Regulating Valve



Position	2	3	4	5	6	7	8
Kv	1.0	1.9	3.2	4.7	6.4	7.3	7.7



Pressure Loss / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_v \sqrt{\Delta p}}{36}$$



Where

Q = Flowrate l/s

Δp = Pressure Loss kPa

Kv = Pressure Loss Co-efficient

1 1/4" ART 27 DZR Metering Station



Signal / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_{vs} \sqrt{\Delta p}}{36}$$



Where

Q = Flowrate l/s

Δp = Signal kPa

K_{vs} = Signal Co-efficient

1 1/4" ART 26 DZR Double Regulating Valve



Pressure Loss / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_v \sqrt{\Delta p}}{36}$$



Where

Q = Flowrate l/s

Δp = Pressure Loss kPa

K_v = Pressure Loss Co-efficient

1 1/2" ART 27 DZR Metering Station



Signal / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_{vs} \sqrt{\Delta p}}{36}$$


Where

Q = Flowrate l/s


Δp = Signal kPa

K_{vs} = Signal Co-efficient

1 1/2" ART 26 DZR Double Regulating Valve



Position	2	3	4	5	6	7	8
Kv	2.5	4.9	8.6	12.9	17.0	19.8	21.5



Pressure Loss / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_v \sqrt{\Delta p}}{36}$$



Where

Q = Flowrate l/s

Δp = Pressure Loss kPa

K_v = Pressure Loss Co-efficient

2" ART 27 DZR Metering Station



Signal / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_{vs} \sqrt{\Delta p}}{36}$$



Where

Q = Flowrate l/s

Δp = Signal kPa

K_{vs} = Signal Co-efficient

2" ART 26 DZR Double Regulating Valve



Pressure Loss / Flowrate

Chart used to determine flowrate from signal measured across orifice

$$Q = \frac{K_v \sqrt{\Delta p}}{36}$$

Where

Q = Flowrate l/s

Δp = Pressure Loss kPa

K_v = Pressure Loss Co-efficient